Lawrence Transit Route, Charge, and Rate Modeling Results



Route Modeling Results



Route Modeling Objectives

- Estimate the energy required and block achievability to operate Gillig 444 kWh battery electric buses on the proposed routes
 - Nominal conditions
 - Strenuous conditions
- Predict energy usage
- Predict range (distance)
- Predict endurance (time)



Route Modeling Approach





Modeling Load Cases & Assumptions

Vehicle	Load Case	Temperature (°F)	Occupants (@150 lbs)	Total Aux Load (kW)	Total Weight (lbs)
Gillig	Nominal	55	12 + Operator	6.5	36,690
444 kWh	Strenuous	12	64 + Operator	23.5	44,490


- Nominal temperature: average temperature outside of hot and cold season temperatures
- Strenuous temperature: average temperature of the 10th percentile maximum and minimum temperatures on the coldest day of the year, January 4th
- Aux load estimates are based on data provided by Gillig and account for temperature data, battery thermal management, and other hotel loads
- Passenger loading based on projected ridership provided by Lawrence Transit
- Occupant weight based on FTA standard



Temperature Assumptions

Nominal Temperature Assumption


Average Spring & Fall Temperature



The daily average high (red line) and low (blue line) temperature, with 25th to 75th and 10th to 90th percentile bands. The thin dotted lines are the corresponding average perceived temperatures.

Strenuous Temperature Assumption


Average temperature of the 10th percentile maximum and minimum temperatures on the coldest day of the year



The hourly average temperature (purple line), with 25th to 75th and 10th to 90th percentile bands. The thin dotted line is the hourly average perceived temperature. Civil twilight and night are indicated by shaded overlays.

Service Energy

- Service energy represents the amount of energy available on the bus for in-service operations
- 80% of the battery capacity is considered usable energy
 - Can select 90% usable instead
- The old battery is representative of degradation to 80%
 - If 90% usable battery capacity is selected, then battery may degrade to 70% of initial capacity
- When operating in the derated SOC range, the bus will start to lose functionality
 - Sluggish movement
 - Load shedding







Selected Routes

Route	Reason for Selection
Route 1	Travels downtown and in East Lawrence.
Route 4	Bridge route
Route 6	Travels downtown and in West Lawrence.
Route 10	Travels along hilly landscape.
Route 11	Route includes many stops.
Route 23	Travels in both East and West Lawrence
Route 43	Campus circulator. Crush Load.
l Line	Travels in both North and South Lawrence



Summary of Collected Route Data

Route	Distance (mi)	Duration (min)	Average Speed* (mph)
Route 1	8.9	49	10.8
Route 4	9.5	47	12.1
Route 6	12.9	66	9.9
Route 10	13.0	51	13.8
Route 11	13.7	90	11.3
Route 23	20.1	91	13.3
Route 43	3.6	22	12.1
l Line	9.0	40	13.6

*Average speed includes time spent at layovers



Simulated Efficiencies

Route	Average Speed* (mph)	Nominal Efficiency** (kWh/mi)	Strenuous Efficiency** - Electric Heating (kWh/mi)	Strenuous Efficiency** - Diesel Heating (kWh/mi)
Route 1	10.8	1.9	3.8	2.0
Route 4	12.1	2.1	3.8	2.3
Route 6	9.9	2.5	4.6	3.0
Route 10	13.8	2.3	4.0	2.7
Route 11	11.3	1.8	3.6	1.5
Route 23	13.3	2.3	3.9	2.7
Route 43	12.1	2.2	4.1	2.1
l Line	13.6	2.3	3.9	2.7


*Average speed includes time spent at layovers

**Nominal and strenuous efficiencies include auxiliary and HVAC energy consumed while bus is stopped at layovers




Electric vs. Diesel Heat

- We assume that the driver has control over the heat source (diesel or electric)
- Under strenuous conditions, no existing blocks are achievable with electric heating
- Diesel heating drastically improves achievability










Gillig 444kWh Endurance






Block Achievability: New Battery


Electric Heat

Diesel Heat



Nominal Load - Achievable Block
Nominal Load - Unachievable Block

Strenuous Load - Unachievable Block








Block Achievability: Old Battery


Electric Heat

Diesel Heat




Nominal Load - Achievable Block
Nominal Load - Unachievable Block

Strenuous Load - Achievable Block
Strenuous Load - Unachievable Block



Cté





Block Achievability

Block		New Battery		Old Battery			
	Nominal	Strenuous Electric Heat	Strenuous Diesel Heat	Nominal	Strenuous Electric Heat	Strenuous Diesel Heat	
101	\checkmark	×	\checkmark	\checkmark	×	\checkmark	
102	\checkmark	×	\checkmark	\checkmark	×	\checkmark	
401	\checkmark	×	\checkmark	×	×	×	
601	×	×	×	×	×	×	
602	×	×	×	×	×	×	
1001	×	×	×	×	×	×	
1002	×	×	×	×	×	×	
1101	\checkmark	×	\checkmark	\checkmark	×	×	
1102	\checkmark	×	\checkmark	×	×	×	
1103	\checkmark	×	\checkmark	\checkmark	×	×	
4301	\checkmark	×	\checkmark	\checkmark	×	\checkmark	
4302	\checkmark	×	\checkmark	\checkmark	×	\checkmark	
4303	\checkmark	×	\checkmark	\checkmark	×	\checkmark	
4304	\checkmark	×	\checkmark	\checkmark	×	\checkmark	



Block Achievability

Block	New Battery			Old Battery			
	Nominal	Strenuous Electric Heat	Strenuous Diesel Heat	Nominal	Strenuous Electric Heat	Strenuous Diesel Heat	
2301	×	×	×	×	×	×	
2302	×	×	×	×	×	×	
2303	×	×	×	×	×	×	
2304	×	×	×	×	×	×	
2305	\checkmark	\checkmark	\checkmark	\checkmark	×	\checkmark	
2306	\checkmark	\checkmark	\checkmark	\checkmark	×	\checkmark	
2307	\checkmark	\checkmark	\checkmark	\checkmark	×	\checkmark	
IL01	×	×	×	×	×	×	
IL02	×	×	×	×	×	×	
IL03	\checkmark	×	\checkmark	\checkmark	×	\checkmark	



Charge and Rate Modeling Results



Charge and Rate Modeling Objectives

- Explore the impact and cost of various charging configurations and load cases
 - Utility rate structure
 - 2022 charging scenarios
 - Futureproofing charging scenarios

Utility Rate Structure


	Day	Time	Classification
Cabadula	M-F	18:00-6:00	Off-Peak
Schedule	M-F	6:00-18:00	On-Peak
	Weekend, 6 Holidays	0:00-23:59	Off-Peak

Fee		Cost
Monthly B	asic Service Fee	\$ 29.00
Energy Charges (\$/kWh)	Off-Peak	\$ 0.0208
	On-Peak	\$ 0.1423
	RECA	\$ 0.0178
	PTS	\$ 0.0010
	TDC	\$ 0.0144
Energy Surcharges (\$/kWh)	ECRR	\$ -
(+) ····)	REPR	\$ -
	EER	\$ 0.0002
	TA	\$ -
	Off-Peak	\$ 0.0542
Total Energy Charges (\$/kWh)	On-Peak	\$ 0.1756




2022 Charging Scenarios

Scenario 1: CPE250 Chargers



Scenario 2: Express Plus with Remote Dispensers



2022 Scenario 1: CPE250

Assumptions:

- 5 bus operation
- Off-peak charging
- Simultaneous charging
- Existing blocks
- 85% availability
- 33% additional grid energy consumption due charger and charge management inefficiencies
- Nominal load case used in monthly estimates
- 1 hour of preconditioning

			Daily Charge Durations (h)			Daily	Charge Co	osts (\$)
Dispenser Number	Dispenser Power (kW)	Block Number	Nominal	Strenuous Electric Heat	Strenuous - Diesel Heat	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat
1	62.5	4304	5.6	9.6	6.6	\$15.83	\$30.28	\$20.26
2	62.5	4301	5.7	9.9	6.8	\$16.39	\$31.34	\$20.94
3	62.5	4302	5.7	9.9	6.8	\$16.39	\$31.34	\$20.94
4	62.5	4303	5.7	9.9	6.8	\$16.39	\$31.34	\$20.94
5	93.75	101	4.5	8.0	4.9	\$17.99	\$36.73	\$20.90
		Average	5.5	9.4	6.4	\$16.60	\$32.20	\$20.80

Average Monthly Estimates (KU Semester)							
Distance	Fuel Cost	Cost/Mile					
10,223 mi	\$1,594	\$0.16					



2022 Scenario 2: Express Plus

Assumptions:

- 5 bus operation
- Off-peak charging
- Simultaneous charging
- Existing blocks
- 85% availability
- 33% additional grid energy consumption due charger and charge management inefficiencies
- Nominal load case used in monthly estimates
- 1 hour of preconditioning

			Daily Charge Durations (h)			Daily	Charge Co	sts (\$)
Dispenser Number	Dispenser Power (kW)	Block Number	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat
1	80	4304	4.6	7.7	5.4	\$15.83	\$30.28	\$20.26
2	120	4301	3.5	5.6	4.0	\$16.39	\$31.34	\$20.94
3	80	4302	4.7	7.9	5.5	\$16.39	\$31.34	\$20.94
4	120	4303	3.5	5.6	4.0	\$16.39	\$31.34	\$20.94
5	120	101	3.7	6.5	4.0	\$17.99	\$36.73	\$20.90
		Average	4.0	6.7	4.6	\$16.60	\$32.20	\$20.80

Average Monthly Estimates (KU Semester)							
Distance	Fuel Cost	Cost/Mile					
10,223 mi	\$1,594	\$0.16					



2022 Charging Scenario Comparison


Daily Char	Average Month				
	Nominal	Strenuous – Electric Heat	Strenuous – Diesel Heat	(KU Sem Metric	Scenario 1 & 2
CPE250 Average	5.5	9.4	6.4	Distance	10,223 mi
Express Plus Average	4.0	6.7	4.6	Fuel Cost	\$1,594
Time Saved with Express Plus (h)	1.5	2.8	1.8	Fuel Cost per Mile	\$0.16
Time Saved with Express Plus (%)	27%	29%	28%		

 If Express Plus is chosen, charge time will be reduced by at least 27% in all load cases




Futureproofing Charging Scenarios

Scenario A: Express Plus with 3 Remote Dispensers



Scenario B: Express Plus with 4 Remote Dispensers



March 3. 2021

Futureproofing Scenario A: 3 Remote Dispensers and 9 Buses Daily Charge Durations (h) Daily Charge Durations (h)

Assumptions:

- 5 bus operation
- Off-peak charging
- Simultaneous charging
- Existing blocks
- 85% availability
- 33% additional grid energy consumption due charger and charge management inefficiencies
- Nominal load case used in monthly estimates
- 1 hour of preconditioning

Average Monthly Estimates (KU Semester)					
Distance	Fuel Cost	Cost/Mile			
20,234 mi	\$3,303	\$0.16			

				Daily Charge Durations (h)			Daily	Charge Co	sts (\$)
	Dispenser Number	Dispenser Power (kW)	Block Number	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat
g	1	40	2305	7.6	12.6	8.7	\$14.71	\$26.50	\$17.90
	2	80	2306	4.3	6.8	4.8	\$14.71	\$26.50	\$17.90
due	3	80	2307	4.3	6.8	4.8	\$14.71	\$26.50	\$17.90
	4	40	4304	8.1	14.4	9.8	\$15.83	\$30.28	\$20.26
ed	5	80	IL03	4.7	7.4	5.3	\$15.83	\$29.22	\$19.70
ing	6	80	4301	4.7	7.9	5.5	\$16.27	\$31.34	\$20.94
	7	40	4302	8.4	14.9	10.1	\$16.39	\$31.34	\$20.94
	8	80	4303	4.7	7.9	5.5	\$16.39	\$31.34	\$20.94
ester)	9	80	101	5.1	9.2	5.5	\$17.99	\$36.73	\$20.90
'Mile 16			Average	5.8	9.8	6.7	\$15.93	\$29.97	\$19.71



Futureproofing Scenario B: 4 Remote Dispensers

and 12 Buses

Assumptions:

- 5 bus operation
- Off-peak charging
- Simultaneous charging
- Existing blocks
- 85% availability
- 33% additional grid energy consumption due charger and charge management inefficiencies
- Nominal load case used in monthly estimates
- 1 hour of preconditioning

Average Mon	thly Estimates (KU Semester)	
Distance	Fuel Cost	Cost/Mile	
31,307 mi	\$4,633	\$0.15	-

				Daily Ch	narge Dura	tions (h)	Daily	Charge Co	sts (\$)
	Dispenser Number	Dispenser Power (kW)	Block Number	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat
	1	40	2305	7.6	12.6	8.7	\$14.71	\$26.50	\$17.90
	2	40	2306	7.6	12.6	8.7	\$14.71	\$26.50	\$17.90
	3	40	2307	7.6	12.6	8.7	\$14.71	\$26.50	\$17.90
	4	80	4304	4.6	7.7	5.4	\$15.83	\$30.28	\$20.26
е	5	40	IL03	8.3	13.9	9.5	\$16.27	\$29.22	\$19.70
	6	40	4301	8.4	14.9	10.1	\$16.39	\$31.34	\$20.94
b	7	40	4302	8.4	14.9	10.1	\$16.39	\$31.34	\$20.94
a	8	80	4303	4.7	7.9	5.5	\$16.39	\$31.34	\$20.94
g	9	40	101	9.1	17.4	10.1	\$17.99	\$36.73	\$20.90
	10	40	102	9.1	17.4	10.1	\$17.99	\$36.73	\$20.90
er)	11	40	1101	9.6	18.5	11.3	\$19.09	\$39.23	\$23.52
ile	12	80	1103	5.3	9.8	6.1	\$19.09	\$39.23	\$23.52

13.3

8.7

7.5

Average



\$20.44

\$16.63

\$32.08

Futureproofing Scenario C: 2 Remote Dual Dispensers and 9 Buses

Assumptions:

- 5 bus operation
- Off-peak charging
- Simultaneous charging
- Existing blocks
- 85% availability
- 33% additional grid energy consumption due charger and charge management inefficiencies
- Nominal load case used in monthly estimates
- 1 hour of preconditioning

			Daily Ch	narge Dura	tions (h)	Daily	Charge Co	osts (\$)
Dispenser Number	Dispenser Power (kW)	Block Number	Nominal	Strenuous - Electric Heat	Strenuous - Diesel Heat	Nominal	Strenuous Electric Heat	Strenuous - Diesel Heat
1	80	2305	4.3	6.8	4.8	\$14.71	\$26.50	\$17.90
2	120	2306, 2307	6.4	9.8	7.1	\$29.43	\$52.99	\$35.79
3	80	4304	4.6	7.7	5.4	\$15.83	\$30.28	\$20.26
4	120	IL03, 4301	6.9	10.9	7.9	\$32.66	\$60.56	\$40.64
5	80	4302	4.7	7.9	5.5	\$16.39	\$31.34	\$20.94
6	120	4303, 101	7.2	12.1	8.0	\$34.38	\$68.06	\$41.84
		Average	5.7	9.2	6.5	\$23.90	\$44.96	\$29.56

Average Monthly Estimates (KU Semester)					
Distance	Fuel Cost	Cost/Mile			
20,234 mi	\$3,303	\$0.16			



Futureproofing Scenario D: 2 Remote Dual Dispensers and 12 Buses

Assumptions:

- 5 bus operation
- Off-peak charging
- Simultaneous charging
- Existing blocks
- 85% availability
- 33% additional grid energy consumption due charger and charge management inefficiencies
- Nominal load case used in monthly estimates
- 1 hour of preconditioning

			Daily Cl	narge Dura	tions (h)	Daily	Charge Co	osts (\$)
Dispenser Number	Dispenser Power (kW)	Block Number	Nominal	Strenuous Electric Heat	Strenuous - Diesel Heat	Nominal	Strenuous - Electric Heat	Stre	enuous - sel Heat
1	80	2305, 2306	8.6	13.6	9.7	\$30.54	\$56.78	\$	38.15
2	120	2307, 4304	6.6	10.3	7.5	\$32.66	\$74.00	\$	40.64
3	80	IL03, 4301	9.4	15.4	10.8	\$32.77	\$62.67	\$	41.89
4	120	4302, 4303	6.9	11.2	8.1	\$35.98	\$115.75	\$	41.80
5	80	101, 102	10.1	18.4	11.1	\$38.18	\$78.46	\$	47.04
6	120	1101, 1103	7.8	13.7	8.8	\$33.26	\$73.44	\$	40.89
		Average	8.2	13.8	9.3	\$33.90	\$76.85	\$	41.73

Average Monthly Estimates (KU Semester)					
Distance	Fuel Cost	Cost/Mile			
31,307 mi	\$4,633	\$0.15			



Futureproofing Charging Scenario Comparison

Daily Charge Duration (h)					
	Nominal	Strenuous – Electric Heat	Strenuous – Diesel Heat		
2022 CPE250 Average	5.5	9.4	6.4		
2022 Express Plus Average	4.0	6.7	4.6		
Futureproofing 3 Dispensers, 9 Buses Average (A)	5.8	9.8	6.7		
Futureproofing 4 Dispensers, 12 Buses Average (B)	7.5	13.3	8.7		
Futureproofing 2 Dispensers, 9 Buses Average (C)	5.7	9.2	6.5		
Futureproofing 2 Dispensers, 12 Buses Average (D)	8.2	13.8	9.3		
2022 vs. 3 Dispensers Charge Time (% time added)	45%	47%	45%		
2022 vs. 4 Dispensers Charge Time (% time added)	89%	100%	89%		
4 Dispensers vs. 3 Dispensers Charge Time (% time added)	31%	36%	30%		
9 Buses 3 vs. 2 Dispensers Charge Time (% time added)	38%	27%	34%		
<u>12 Buses 4 vs. 2 Dispensers Charge Time (% time added)</u>	21%	13%	19%		



- As more dispensers are added, required charge time increased due to:
 - Less power delivery per dispenser
 - Added blocks consume more energy
- Despite yielding lower average charge durations, using 2 dispensers with 9 or 12 buses increases the maximum dispenser charging time
 - Risk failing to charge before start of service
 - Risk paying on-peak energy prices

Average Monthly Estimates (KU Semester)						
Metric	Scenario A,C (9 Buses)	Scenario B,D (12 Buses)				
Distance	23,937 mi	37,139 mi				
Fuel Cost	\$3,303	\$4,633				
Fuel Cost per Mile	\$0.16	\$0.15				

Contact Information

Darryl Oswald Engineering Associate darryl@cte.tv

Christiane Walker Engineering Consultant christiane@cte.tv Matt Boothe Senior Engineering Consultant matt@cte.tv

Chase Stell

Associate chase@cte.tv

